



**Government
of South Australia**

Department for
Energy and Mining

NOTICE OF EXEMPTION

UNDER THE *ELECTRICITY (GENERAL) REGULATIONS 2012*, REGULATIONS UNDER THE *ELECTRICITY ACT 1996*

Under Regulation 89(1) of the *Electricity (General) Regulations 2012* I grant exemption from Regulation 53 which would otherwise require compliance with AS/NZS 3000 and any other Australian Standard or Australian/New Zealand Standard called up by AS/NZS 3000.

This exemption applies only to devices and installations which meet all of the following conditions:

- Inverters are certified to AS/NZS 4777.2:2020 amendment 1
- Inverters are equipped with energy storage ports as considered by AS/NZS 4777.2:2020 amendment 1
- Installations are completed before 1 May 2026

Other than the requirement for these devices to be certified to AS/NZS 4777.2:2020 amendment 2 – all other requirements under AS/NZS 3000 apply.

A handwritten signature in blue ink, appearing to read 'R J Faunt'.

Rob Faunt
TECHNICAL REGULATOR

Dated 27 October 2025.